

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY  
CONDITION CERTIFICATE**

No. 1155Dated: 05.04.2024

It is certified that an inspection team headed by Manoj Bhaskar E.E.  
(Name of Officers with designation) from Public Health Engg. Deptt. Mandla  
PHED inspected the **Bellwether International School, Phoolsagar, Mandla, Dist Mandla, MP** on  
05.04.2024 and on the basis of Water Test Report (Attached) bearing no. 1642  
dated 05.04.24 of Distt. Water Testing Laboratory Mandla  
(PHED Lab) certified that the **Bellwether International School, Phoolsagar, Mandla, Dist Mandla, MP** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 1 year

Signature with seal

:-

Executive Engineer  
Public Health Engg. Division

Name

:-

Manoj Bhaskar Mandla (M.P.)

Designation

:-

Executive EngineerName & address of the office/Department: - Public Health Engineering Department

To,

Bellwether International School,  
Phoolsagar, Mandla, Dist Mandla, MP

(Name and address of the institution)

Note: The certificate is to be issued by authorized officer / PHED Lab/local bodies

  
Pdt. Shailesh Mishra  
CHAIRMAN  
SR EDUCATION DEV SOCIETY MANDLA

  
Principal  
Bellwether International School  
Mandla

**DISTRICT WATER TESTING LABORATORY**  
office of the Assistant Engineer, Public Health Engg. Sub Division Mandla (M.P.)


**WATER TESTING REPORT**


Report No. 1643	Date-05/04/2024	District - Mandla	
Your Ref. No. BWIS/2024-25/PHE-01	Date -04/04/2024	Village & Location	Block
To,	M/S. Bellwether International School Phool Sagar Mandla	Phool Sagar Villege In the campus of Bellwether School R.O. Treated Water Sample	Mandla
Sample Collected By - Mr. Suneet Kumar Goutam	Date of Collection 04/04/2024		
Source - R.O. water	Date of Receipt - 04/04/2024		
Date of Testing - 05/04/2024	Test Conducted by - S.P. Shukla (Chemist)		

S. No.	Characteristic	Unit	Acceptable	Cause for rejection	1	2	3	4
<b>PHYSICAL TEST</b>								
1	Turbidity	NTU	1.0	5.00	0.00			
2	Colour	Pt. Cobalt	5.0	25	Colourless			
3	Test & Odour		Unobjectionable	Unobjectionable	-			
<b>CHEMICAL TEST</b>								
4	pH	-	7.0 to 8.5	<6.5or>9.2	6.56			
5	conductivity				50.37			
6	Alkalinity	mg/l	200	600	12.0			
7	Chloride (as Cl)	mg/l	250	1000	7.0			
8	Nitrates	mg/l	45	45	0.00			
9	Total Hardness as (Caco3)	mg/l	200	600	30.8			
10	Calcium As Ca	mg/l	75	200	17.6			
11	Magnesium as Mg		30	100	12.4			
12	Total Dissolved Solids	mg/l	500	2000	26.4			
13	Iron (as Fe)	mg/l	0.3	1.0	0.00			
14	Fluoride (as F)	mg/l	1.0	1.5	0.03			
15	Sulphates (as SO4)	mg/l	200	400	0.00			
16	Arsenic	mg/l	0.01	0.01	-			
17	Manganese	mg/l	0.1	0.3	0.0			
18	Residual Chorine	mg/l	0.2	1.0	-			
<b>BACTERIOLOGICAL TEST</b>								
19	Coliform ogranigms	MPN/100ml	0	0	-			
20	Faecal Coliform	MPN/100ml	0	0	-			
Remark-	Water sample is potable -							

Note -

- (1) Samples are not collected by us.
- (2) Not to be produced at Court of law
- (3) We do not take any responsibility for deviation in test result due to wrong collection of sample

  
CHEMIST  
Public Health Engg. Sub Division  
Mandla (M.P.)

  
ASSISTANT ENGINEER  
Public Health Engg. Sub Division  
Mandla (M.P.)

  
"Pdt. Shailesh Mishra"  
CHAIRMAN  
SR EDUCATION DEV SOCIETY MANDLA

  
Principal  
Bellwether International School  
Mandla